

Western Treatment Plant Recycled Water Quality for February 2014 – Post disinfection.

| Metals analysis in mg/L | LTV Limit * | STV Limit * | Median |
|-------------------------|------------------|------------------|----------|
| Aluminium | 5 | 20 | 0.03 |
| Antimony | | | 0.002 |
| Arsenic | 0.1 | 2 | 0.002 |
| Barium | | | 0.004 |
| Beryllium | 0.1 | 0.5 | < 0.001 |
| Boron | 0.5 | | 0.16 |
| Cadmium | 0.01 | 0.05 | < 0.0002 |
| Chromium | 0.1 | 1 | < 0.001 |
| Cobalt | 0.05 | 0.1 | 0.001 |
| Copper | 0.2 | 5 | 0.007 |
| Iron | 0.2 | 10 | < 0.1 |
| Lead | 2 | 5 | < 0.001 |
| Lithium | 2.5 [#] | 2.5 [#] | 0.01 |
| Manganese | 0.2 | 10 | < 0.1 |
| Mercury | 0.002 | 0.002 | < 0.0001 |
| Molybdenum | 0.01 | 0.05 | 0.004 |
| Nickel | 0.2 | 2 | 0.008 |
| Selenium | 0.02 | 0.05 | < 0.01 |
| Silver | | | < 0.001 |
| Thorium | | | < 0.002 |
| Tin | | | < 0.001 |
| Vanadium | 0.1 | 0.5 | 0.001 |
| Zinc | 2 | 5 | 0.014 |

* ARMCANZ / ANZECC Long Term trigger Value (up to 100 years)

* ARMCANZ / ANZECC Short Term trigger Value (up to 20 years)

Lithium STV & LTV for citrus crops is 0.075 mg/l

| Physical Chemistry | LTV Limit * | STV Limit * | Median |
|---------------------------------------|----------------|----------------|--------|
| pH | | | 7.5 |
| BOD5 (mg/L) | | | < 2 |
| Suspended Solids (mg/L) | | | 2 |
| E.coli post disinfection (orgs/100mL) | | | 2.5 |
| Total Nitrogen (mg-N/L) | 5 | 25-125 | 6.2 |
| Nitrite (mg-N/L) | | | < 0.01 |
| Nitrate (mg-N/L) | | | 11 |
| Total Phosphorous (mg-P/L) | 0.05 | 0.8-12 | 9.6 |

| Salinity Indicators | Median |
|-------------------------|--------|
| Sodium (mg/L) | 290 |
| Potassium (mg/L) | 32 |
| Calcium (mg/L) | 34 |
| Magnesium (mg/L) | 30 |
| SAR | 8.7 |
| Chloride (mg-Cl/L) | 480 |
| TDS (mg/L) | 1300 |
| TDS Inorganic (mg/L) | 1100 |
| TDS Organic (mg/L) | 200 |
| Electrical Conductivity | 2000 |

| Aesthetic Indicator | Median |
|----------------------|--------|
| Colour (Pt/co units) | 10 |