

## Western Treatment Plant Recycled Water Quality for May 2011 – Post disinfection

Metals analysis in mg/L	LTV limit *	STV limit *	Median
Aluminium	5	20	< 0.01
Antimony			0.002
Arsenic	0.1	2	0.002
Barium			0.0045
Beryllium	0.1	0.5	< 0.001
Boron	0.5		0.18
Cadmium	0.01	0.05	< 0.0002
Chromium	0.1	1	< 0.001
Cobalt	0.05	0.1	0.001
Copper	0.2	5	0.0045
Iron	0.2	10	0.02
Lead	2	5	< 0.001
Lithium #	2.5	2.5	< 0.02
Manganese	0.2	10	0.014
Mercury	0.002	0.002	< 0.0001
Molybdenum	0.01	0.05	0.0025
Nickel	0.2	2	0.0095
Selenium	0.02	0.05	< 0.001
Silver			< 0.001
thorium			< 0.002
Tin			< 0.001
vanadium	0.1	0.5	< 0.001
Zinc	2	5	0.022

Physical chemistry	LTV limit *	STV limit *	Median
pH			7.4
BOD5 mg/L			< 2
Suspended solids mg/L			< 2
E.Coli post disinfection orgs/100mL			2
Total Nitrogen mg-N/L	5	25-125	24
as Nitrite mg-N/L			< 0.01
as Nitrate mg-N/L			23
Total Phosphorous mg-P/L	0.05	0.8-12	9.2
<b>Salinity indicators</b>			
Median			
sodium mg/L			290
potassium mg/L			29
calcium mg/L			40
magnesium mg/L			29
SAR			8.7
chloride mg-Cl/L			420
TDS mg/L			1100
TDS (inorganic) mg/L			940
TDS (organic) mg/L			130
Electrical Conductivity			1900
<b>Aesthetic indicator</b>			
Median			
colour Pt/co units			10

\* ARMCANZ / ANZECC Long Term trigger Value (up to 100 years)  
 \* ARMCANZ / ANZECC Short Term trigger Value (up to 20 years)  
 # Lithium STV & LTV for citrus crops is 0.075 mg/l