

## Western Treatment Plant Recycled Water Quality

Metals analysis in mg/L	LTV Limit *	STV Limit *	Median	Physical Chemistry	LTV Limit *	STV Limit *	Median
Aluminium	5	20	0.02	pH			7.2
Antimony			0.002	BOD5 (mg/L)			1
Arsenic	0.1	2	0.001	Suspended Solids (mg/L)			1
Barium			0.005	<i>E.coli</i> post disinfection (orgs/100mL)			0
Beryllium	0.1	0.5	0.0005	Somatic Coliphage			0.5
Boron	0.5		0.18	Total Nitrogen (mg-N/L)	5	25-125	18
Cadmium	0.01	0.05	0.0001	Nitrite (mg-N/L)			0.06
Chromium	0.1	1	0.0005	Nitrate (mg-N/L)			17
Cobalt	0.05	0.1	0.001	Total Phosphorous (mg-P/L)	0.05	0.8-12	9.1
Copper	0.2	5	0.005				
Iron	0.2	10	0.05	<b>Salinity Indicators</b>			<b>Median</b>
Lead	2	5	0.0005	Sodium (mg/L)			240
Lithium	2.5 <sup>#</sup>	2.5 <sup>#</sup>	0.1	Potassium (mg/L)			29
Manganese	0.2	10	0.053	Calcium (mg/L)			28
Mercury	0.002	0.002	0.00005	Magnesium (mg/L)			23
Molybdenum	0.01	0.05	0.002	SAR			8.2
Nickel	0.2	2	0.009	Chloride (mg-Cl/L)			330
Selenium	0.02	0.05	0.001	TDS (mg/L)			790
Silver			0.0005	TDS Inorganic (mg/L)			700
Thorium			0.001	TDS Organic (mg/L)			90
Tin			0.0005	Electrical Conductivity			1700
Vanadium	0.1	0.5	0.001				
Zinc	2	5	0.021	<b>Aesthetic Indicator</b>			<b>Median</b>
				Colour (Pt/co units)			14
* ARMCANZ / ANZECC Long Term trigger Value (up to 100 years)							
* ARMCANZ / ANZECC Short Term trigger Value (up to 20 years)							
# Lithium STV & LTV for citrus crops is 0.075 mg/l							